

CERTIFICATE OF COMPLETION

Northwest Booster Station

Ankeny, Iowa

October 21, 2019

This is to certify that the construction improvements on the **Northwest Booster Station** project have been completed in substantial compliance with the plans and specifications for the project. The final contract amount is **\$2,347,376.15**. I hereby recommend acceptance of the project.

The Contractor, Engineer and Owner have noted that the pressure sensor on the supply header has a small leak. Due to the need to take the entire booster station off line, all parties have agreed to allow this to remain in its current condition. If this leak persists to the level that the booster station is not properly functioning, the Contractor has agreed to make necessary repairs at that time. If this leak is still present in any capacity after the construction of a planned water tower, the booster station could be taken off line and the Contractor has agreed to make the necessary repairs at that time.

Respectfully submitted,

A handwritten signature in blue ink, appearing to read 'H.R. Veenstra Jr.', with a stylized flourish at the end.

H.R. Veenstra Jr.
President, Project Manager
Veenstra & Kimm, Inc.
Iowa License Number 9037